



FLUROPON®

CERTIFIED LABORATORY  
TEST REPORT

FILM HARDNESS

## PENCIL HARDNESS

TEST PROCEDURES:	FILM HARDNESS BY PENCIL TEST PER ASTM D 3363
PRODUCT TESTED:	VALSPAR FLUROPON COATING
TESTS RESULTS:	PENCIL HARDNESS (GOUGH AND SCRATCH HARDNESS) IS HB MINIMUM USING EAGLE TURQUOISE PENCILS
SAMPLE NUMBER:	433B365
LOCATION:	THE VALSPAR CORPORATION FT. MYERS, FL

The VALSPAR CORPORATION certifies these tests to be true and accurate and performed by our laboratory.